

Britney Becker

From: Geoff Aitken
Sent: Wednesday, August 16, 2023 12:35 PM
To: Britney Becker
Cc: CBO - Karl Schipprack
Subject: RE: B03.2023 & B15.2023 - Request for Comments

Hi Britney,

Similar comments as the other projects on Park St:

- ensure adequate hydrant spacing, may need to add a fire hydrant (yellow)
- appears sanitary connection is by a low pressure forcemain (grinder pump), given the other developments occurring on Park St the accumulated impact would suggest that consideration should be given to a proper sewage lift station
- water services are to be minimum 25 mm diameter
- water & sewer laterals to compete with tracer wire from main to property line

Geoff Aitken, CET
Manager of Public Works

Municipality of West Grey
402813 Grey Road 4
RR 2 Durham, ON N0G 1R0
519-369-2200 ext. 227
www.westgrey.com || @OurWestGrey

Confidentiality Notice: This e-mail message and attachments, if any, are sent by a Third Party Administrator for the sole use of the intended recipient(s). It may contain information that is privileged and/or confidential. If you are not the intended recipient, please notify the sender immediately by reply email and destroy this communication. Thank you.

From: Britney Becker <bbecker@westgrey.com>
Sent: August 11, 2023 2:24 PM
To: Shawn Edwards <sedwards@westgrey.com>; CBO - Karl Schipprack <cbo@westgrey.com>; Phil Schwartz <pschwartz@westgrey.com>; Geoff Aitken <publicworks@westgrey.com>; building <building@westgrey.com>
Subject: B03.2023 & B15.2023 - Request for Comments

Good afternoon,

Please find notice of hearing for applications for consent for the above noted files attached.

The applications are scheduled to be heard at the September 5th committee of adjustment meeting. Your comments would be appreciated by August 14th.

Additional contents of the files can be found in the T-drive – D10 Severances – 2023 – B03.2023 & B15.2023

Kind regards,

Britney Becker
Plans Examiner & Building Inspector

Municipality of West Grey

402813 Grey Road 4
RR 2 Durham, ON N0G 1R0
519-369-2200 ext. 248
www.westgrey.com || @OurWestGrey

Confidentiality Notice: This e-mail message and attachments, if any, are sent by a Third Party Administrator for the sole use of the intended recipient(s). It may contain information that is privileged and/or confidential. If you are not the intended recipient, please notify the sender immediately by reply email and destroy this communication. Thank you.